

Chapter 31

Some Aspects of Energy Efficiency for Refrigeration and Air Conditioning

Abdeen Mustafa Omer
Energy Research Institute (ERI), UK

ABSTRACT

Over the years, all parts of a commercial refrigerator, such as the compressor, heat exchangers, refrigerant, and packaging, have been improved considerably due to the extensive research and development efforts carried out by academia and industry. However, the achieved and anticipated improvement in conventional refrigeration technology are incremental since this technology is already nearing its fundamentals limit of energy efficiency is described is 'magnetic refrigeration' which is an evolving cooling technology. The word 'green' designates more than a colour. It is a way of life, one that is becoming more and more common throughout the world. An interesting topic on 'sustainable technologies for a greener world' details about what each technology is and how it achieves green goals. Recently, conventional chillers using absorption technology consume energy for hot water generator but absorption chillers carry no energy saving. With the aim of providing a single point solution for this dual purpose application, a product is launched but can provide simultaneous chilling and heating using its vapour absorption technology with 40% saving in heating energy. Using energy efficiency and managing customer energy use has become an integral and valuable exercise. The reason for this is green technology helps to sustain life on earth. This not only applies to humans but to plants, animals and the rest of the ecosystem. Energy prices and consumption will always be on an upward trajectory. In fact, energy costs have steadily risen over last decade and are expected to carry on doing so as consumption grows. This article discusses the potential for such integrated systems in the stationary and portable power market in response to the critical need for a cleaner energy technology for communities. Throughout the theme several issues relating to renewable energies, environment and sustainable development are examined from both current and future perspectives.

DOI: 10.4018/978-1-4666-9644-0.ch031

INTRODUCTION

This section describes the different methods and techniques for providing energy for heating and cooling systems. It also, covers the optimisation and improvement of the operation conditions of the heat cycles and the performance of the ground source heat pump systems (GSHPs).

With the improvement of people's living standards and the development of economies, heat pumps have become widely used for air conditioning. The driver to this was that environmental problems associated with the use of refrigeration equipment, the ozone layer depletion and global warming are increasingly becoming the main concerns in developed and developing countries alike. With development and enlargement of the cities in cold regions, the conventional heating methods can severely pollute the environment. In order to clean the cities, the governments drew many measures to restrict citizen heating by burning coal and oil and encourage them to use electric or gas-burning heating. New approaches are being studied and solar-assisted reversible absorption heat pump for small power applications using water-ammonia is under development (Luo, Tondeur, Le Gall, & Corbel, 2007).

An air-source heat pump is convenient to use and so it is a better method for electric heating. The ambient temperature in winter is comparatively high in most regions, so heat pumps with high efficiency can satisfy their heating requirement. On the other hand, a conventional heat pump is unable to meet the heating requirement in severely cold regions anyway, because its heating capacity decreases rapidly when ambient temperature is below -10°C . According to the weather data in cold regions, the air-source heat pump for heating applications must operate for long times with high efficiency and reliability when ambient temperature is as low as -15°C . Hence, much researches and developments have been conducted to enable heat pumps to operate steadily with high efficiency and reliability in low temperature environments (Luo, Fan, & Tondeur, 2007). For example, the burner of a room air conditioner, which uses kerosene, was developed to improve the performance in low outside temperature (Philappacopoulos, & Berndt, 2001). Similarly, the packaged heat pump with variable frequency scroll compressor was developed to realise high temperature air supply and high capacity even under the low ambient temperature of -10 to -20°C (Jo, Katsumi, Benson, & Edil, 2001). Such a heat pump systems can be conveniently used for heating in cold regions. However, the importance of targeting the low capacity range is clear if one has in mind that the air conditioning units below 10 kW cooling account for more than 90% of the total number of units installed in the EU (Anandarajah, 2003).

EARTH-ENERGY SYSTEMS (EESs)

The earth-energy systems, EESs, have two parts; a circuit of underground piping outside the house, and a heat pump unit inside the house. And unlike the air-source heat pump, where one heat exchanger (and frequently the compressor) is located outside, the entire GSHP unit for the EES is located inside the house.

The outdoor piping system can be either an open system or closed loop. An open system takes advantage of the heat retained in an underground body of water. The water is drawn up through a well directly to the heat exchanger, where its heat is extracted. The water is discharged either to an aboveground body of water, such as a stream or pond, or back to the underground water body through a separate well. Closed-loop systems, on the other hand, collect heat from the ground by means of a continuous loop of piping buried underground. An antifreeze solution (or refrigerant in the case of a direct expansion 'DX')

22 more pages are available in the full version of this document, which may be purchased using the "Add to Cart" button on the publisher's webpage:

www.igi-global.com/chapter/some-aspects-of-energy-efficiency-for-refrigeration-and-air-conditioning/147539

Related Content

A Gravitational Search Algorithm Approach for Optimizing Closed-Loop Logistics Network

Abdolhossein Sadrnia, Hossein Nezamabadi-Pour, Mehrdad Nikbakhtand Napsiah Ismail (2013). *Meta-Heuristics Optimization Algorithms in Engineering, Business, Economics, and Finance* (pp. 616-638).

www.irma-international.org/chapter/gravitational-search-algorithm-approach-optimizing/69899

Performances of Adaptive Cuckoo Search Algorithm in Engineering Optimization

Pauline Ongand S. Kohshelan (2016). *Handbook of Research on Modern Optimization Algorithms and Applications in Engineering and Economics* (pp. 676-699).

www.irma-international.org/chapter/performances-of-adaptive-cuckoo-search-algorithm-in-engineering-optimization/147534

Assessing Algorithmic Performance by Frontier Analysis: A DEA Approach

Jose Humberto Ablanedo-Rosasand Cesar Rego (2018). *International Journal of Applied Metaheuristic Computing* (pp. 78-94).

www.irma-international.org/article/assessing-algorithmic-performance-by-frontier-analysis/193204

Subspace Discovery for Disease Management: A Case Study in Metabolic Syndrome

Josephine Namayanjaand Vandana P. Janeja (2011). *International Journal of Computational Models and Algorithms in Medicine* (pp. 38-59).

www.irma-international.org/article/subspace-discovery-disease-management/53720

Introduction and State-of-the-Art Review of Optimum Design of Reinforced Concrete Structures: Overview for Optimum Design RC Structures

(2020). *Metaheuristic Approaches for Optimum Design of Reinforced Concrete Structures: Emerging Research and Opportunities* (pp. 1-35).

www.irma-international.org/chapter/introduction-and-state-of-the-art-review-of-optimum-design-of-reinforced-concrete-structures/251013