

Chapter 6

Characteristics and Suppression of Space Charge in Polyethylene

ABSTRACT

In HVDC transmission systems, the space charge accumulation of polyethylene (PE) insulation is a major problem that threatens the safe and stable operation of cables. In this chapter, nanoparticles and voltage stabilizers are used to inhibit space charge in PE, which has excellent compatibility with PE. To study the thermal, mechanical, and electrical properties of the samples, differential scanning calorimetry (DSC) testing, tensile testing, breakdown, and conductivity property were measured separately. Besides, the space charge behavior based on the PEA method was studied, and the carrier mobility was calculated by the space charge depolarization process. The experimental results indicate that PE modified by graphene oxide (GO) nanoparticles and the voltage stabilizers demonstrate the suppression of space charge accumulation in PE insulation, which has less space charge accumulation than pure PE. The results show that graphene oxide and the preferred stabilizer have broad prospects in HVDC cable applications.

INTRODUCTION

Cross-linked polyethylene (XLPE) is a significant insulation used in high-voltage cable, which plays a role in HVDC transmission (Bjorlow-Larsen, 2000). Yet, space charge accumulation problem in the XLPE may be caused by-products during the manufacturing process, leading to the insulation aging and greatly limiting the application of XLPE in HVDC cables (Montanari, 2005). Since its first introduction, nanocomposites have given rise to a new research frenzy as a recognized method for solving the space charge accumulation in polymers (Lewis, 1994). A number of studies have been conducted on methods of adding nano-particles into LDPE matrices, which have been proved to improve the space charge characteristics. For the LDPE/MgO composites, the doping of the MgO nanoparticles is effective for the space charge suppression under the stretching conditions (Wang, 2016). Moreover, studies have shown that by adding an appropriate amount of MgO nanoparticles to polyethylene, space charge can be suppressed. Besides, the DC breakdown strength of the composite can be improved (Peng, 2015). The inhibition of space charge in the nanocomposites may be due to the interface between the filler and the matrix, based on which a model of multi core has been put forward, helping to explain existed research results and has been extensively recognized. (Tanaka, 2005). The nanoparticles can solve the problem of space charge accumulation of nanocomposites to some extent. Nevertheless, the amount of additives is relatively high, which will lead to agglomeration of nanoparticles and may cause unpredictable defects in composite materials. Therefore, there is an urgent need to develop new nano-fillers to achieve the purpose of inhibiting the space charge in the polymer by less added content.

Graphene oxide (GO) is one of the most major derivatives of the graphene, which has a single layer structure with a thickness as only one atom. The specific surface area of GO is large, which makes small doping amount possible. GO also possess well properties due to the destruction of its sp² bonding network (Novoselov, 1998). These excellent properties have made GO a widespread concern since its discovery and an ideal filler for the fabrication of nano dielectric materials (Novoselov, 2004). The electrical and mechanical properties of GO and GNP doped polyurethane nanocomposites are superior

23 more pages are available in the full version of this document, which may be purchased using the "Add to Cart" button on the publisher's webpage: www.igi-global.com/chapter/characteristics-and-suppression-of-space-charge-in-polyethylene/243861

Related Content

Loss Minimization in Active Distribution Network

Bawoke Simachew (2020). *Handbook of Research on New Solutions and Technologies in Electrical Distribution Networks* (pp. 119-135).

www.irma-international.org/chapter/loss-minimization-in-active-distribution-network/245641

Energy Performance of Renewable Technologies: LR of PV Panels With Analysis of Their Efficiency in Relation to Internal and External Factors

Aydin Tabrizi (2020). *International Journal of Energy Optimization and Engineering* (pp. 41-56).

www.irma-international.org/article/energy-performance-of-renewable-technologies/259976

IoT Big Data Security, Privacy and Challenges Related to Smart Grid

Kimmi Kumariand M. Mrunalini (2022). *Research Anthology on Smart Grid and Microgrid Development* (pp. 368-379).

www.irma-international.org/chapter/iot-big-data-security-privacy-and-challenges-related-to-smart-grid/289888

Bluetooth-Tracing RSSI Sampling Method as Basic Technology of Indoor Localization for Smart Grid

(2018). *Smart Grid Test Bed Using OPNET and Power Line Communication* (pp. 95-112).

www.irma-international.org/chapter/bluetooth-tracing-rssi-sampling-method-as-basic-technology-of-indoor-localization-for-smart-grid/187440

Decentralized Energy Management System Enhancement for Smart Grid

Hadjira Belaidiand Zakaria Rabiai (2022). *Research Anthology on Smart Grid and Microgrid Development* (pp. 77-90).

www.irma-international.org/chapter/decentralized-energy-management-system-enhancement-for-smart-grid/289874