


Quantum-Behaved Bat Algorithm for Solving the Economic Load Dispatch Problem Considering a Valve-Point Effect


Pandian Vasant, Universiti Teknologi Petronas, Seri Iskandar, Malaysia

Fahad Parvez Mahdi, University of Hyogo, Kobe, Japan

 <https://orcid.org/0000-0002-0081-7358>

Jose Antonio Marmolejo-Saucedo, Universidad Panamericana, Facultad de Ingeniería, Ciudad de México, Mexico

Igor Litvinchev, Nuevo Leon State University, San Nicolás de los Garza, Mexico

 <https://orcid.org/0000-0002-1850-4755>

Roman Rodriguez Aguilar, Universidad Panamericana, Escuela de Ciencias Económicas y Empresariales, Ciudad de México, Mexico

Junzo Watada, Universiti Teknologi Petronas, Seri Iskandar, Malaysia

ABSTRACT

Quantum computing-inspired metaheuristic algorithms have emerged as a powerful computational tool to solve nonlinear optimization problems. In this paper, a quantum-behaved bat algorithm (QBA) is implemented to solve a nonlinear economic load dispatch (ELD) problem. The objective of ELD is to find an optimal combination of power generating units in order to minimize total fuel cost of the system, while satisfying all other constraints. To make the system more applicable to the real-world problem, a valve-point effect is considered here with the ELD problem. QBA is applied in 3-unit, 10-unit, and 40-unit power generation systems for different load demands. The obtained result is then presented and compared with some well-known methods from the literature such as different versions of evolutionary programming (EP) and particle swarm optimization (PSO), genetic algorithm (GA), differential evolution (DE), simulated annealing (SA) and hybrid ABC_PSO. The comparison of results shows that QBA performs better than the above-mentioned methods in terms of solution quality, convergence characteristics and computational efficiency. Thus, QBA proves to be an effective and a robust technique to solve such nonlinear optimization problem.

KEYWORDS

Economic Load Dispatch, Non-Convex, Optimization, Quantum-Behaved Bat Algorithm, Valve-Point Effect

DOI: 10.4018/IJAMC.2020070102

Copyright © 2020, IGI Global. Copying or distributing in print or electronic forms without written permission of IGI Global is prohibited.

INTRODUCTION

Thermal plants mainly utilize fossil fuels like coal, gas and oil to generate electricity. Capacity to deliver fossil fuels as per their growing demand is very much limited due to the shortage of fossil fuel supply and lack of adequate infrastructures (Mahdi, Vasant, Kallimani, & Abdullah-Al-Wadud, 2016). Moreover, fossil fuels are not always easily accessible to all as the reserves of the fossil fuels are concentrating into a small number of countries. Furthermore, the reserves of the fossil fuels are declining and it will be distinct and too expensive in near future. Thus, economic load dispatch (ELD) plays one of the most crucial parts in electrical power generation system. ELD deals with the minimization of fuel cost, while satisfying all other constraints (Wood & Wollenberg, 2012). The simplification of traditional ELD problem fails to offer satisfactory results in real-world system as they consider that the efficiency of power plant increases linearly or quadratically. However, in real-world system separate nozzle groups help the valves to control the steam entering the turbine. The system tries to achieve its highest efficiency by activating the valves in a sequential way and thus resulting a rippled efficiency curve. This phenomenon is known as valve-point effect. In this research, valve-point effect is considered as a practical operation constraint of generator. Considering valve-point effect helps to model ELD problem more accurately and closer to actual power generation system at the cost of adding extra complexities in the system.

Traditional methods like Newton-Raphson (Lin, Chen, & Huang, 1992), linear and nonlinear programming techniques (Momoh, El-Hawary, & Adapa, 1999) were used to solve ELD problem, where the ELD problem is represented using linear quadratic function. They proved to be fast and reliable against linear ELD problem. But, when considering the nonlinear characteristics of power system like consideration of valve-point effect, the traditional methods were proved to be ineffective and inefficient (Chen & Wang, 1993). They are prone to trap into the local optima and have sensitivity to the initial point (Mahdi, Vasant, Kallimani, Watada, et al., 2017).

Different heuristic and metaheuristic techniques have later used to overcome the shortcomings of the traditional methods to solve nonlinear ELD problem. Genetic algorithm (GA) (Walters & Sheble, 1993), simulated annealing (SA) (Wong & Fung, 1993), evolutionary programming (EP) (Yang, Yang, & Huang, 1996), tabu search (TS) (Lin, Cheng, & Tsay, 2002), enhanced Lagrangian artificial neural network (ELANN) (S. C. Lee & Kim, 2002), generalized ant colony optimization (GACO) (Hou, Wu, Lu, & Xiong, 2002), improved fast evolutionary program (IFEP) (Chakrabati, Choudhury, Chattopadhyay, Sinha, & Ravi, 2003), particle swarm optimization (PSO) (Park, Lee, Shin, & Lee, 2005), pattern search (PS) method (Al-Sumait, Al-Othman, & Sykulski, 2007), Biogeography based optimization (BBO) (Roy, Ghoshal, & Thakur, 2009), improved harmony search (IHS) (Coelho & Mariani, 2009b), chaotic artificial immune network (CAIN) (Coelho & Mariani, 2009a), bat algorithm (BA) (Sakthivel, Natarajan, & Gurusamy, 2013), chaotic teaching-learning-based optimization with Lévy flight (CTLBO) (X. He, Rao, & Huang, 2016) and swarm based mean-variance mapping optimization (MVMO^s) (Khoa, Vasant, Singh, & Dieu, 2017) are some of the techniques used for solving nonlinear ELD problem. These methods can provide global or near global solutions (Meng, Wang, Dong, & Wong, 2010). However, they cannot always guarantee finding global solutions in finite computational time and many problem specific parameters to tune.

Researchers propose and develop hybrid methods to avoid the problems found in the conventional and stand-alone heuristic/metaheuristic methods. They start with PSO-EP (Sinha & Purkayastha, 2004), PSO-sequential QP (SQP) (Victoire & Jeyakumar, 2005), chaotic differential evolution (CDE)-quadratic programming (QP) (dos Santos Coelho & Mariani, 2006), GA-SQP (He, Wang, & Mao, 2008), chaotic PSO- implicit filtering local search (IFLS) method (Coelho & Mariani, 2009c), variable scaling hybrid differential evolution (VSHDE) (Chiou, 2009), GA-PSO (Jiang, Xu, Gong, & Chen, 2009) and GA-PS-SQP (Alsumait, Sykulski, & Al-Othman, 2010), and finished with fuzzy adaptive PSO-Nelder Mead (FAPSO-NM) (Niknam, 2010), cultural algorithm- self-organizing migrating algorithm (CSOMA) (L. D. S. Coelho & Mariani, 2010), interior point method (IPM)-DE (Duvvuru

15 more pages are available in the full version of this document, which may be purchased using the "Add to Cart" button on the publisher's webpage: www.igi-global.com/article/quantum-behaved-bat-algorithm-for-solving-the-economic-load-dispatch-problem-considering-a-valve-point-effect/251837

Related Content

Pseudorandom Number Generators Based on Cellular Automata With the Hexagonal Coverage

(2018). *Formation Methods, Models, and Hardware Implementation of Pseudorandom Number Generators: Emerging Research and Opportunities* (pp. 139-156).

www.irma-international.org/chapter/pseudorandom-number-generators-based-on-cellular-automata-with-the-hexagonal-coverage/190217

Multi-Objective Generation Scheduling Using Genetic-Based Fuzzy Mathematical Programming Technique

Abdellah Derghaland Nouredine Goléa (2014). *Handbook of Research on Novel Soft Computing Intelligent Algorithms: Theory and Practical Applications* (pp. 450-474).

www.irma-international.org/chapter/multi-objective-generation-scheduling-using-genetic-based-fuzzy-mathematical-programming-technique/82701

A Genetic Algorithm-Based Neuro-Fuzzy Controller for Unmanned Aerial Vehicle Control

Boumediene Selma, Samira Chouraquiand Belkacem Selma (2022). *International Journal of Applied Metaheuristic Computing* (pp. 1-23).

www.irma-international.org/article/a-genetic-algorithm-based-neuro-fuzzy-controller-for-unmanned-aerial-vehicle-control/292505

Power Flow Modeling in Power System With Multiple FACTS Controller

(2019). *Optimal Power Flow Using Evolutionary Algorithms* (pp. 194-209).

www.irma-international.org/chapter/power-flow-modeling-in-power-system-with-multiple-facts-controller/212081

The Dynamics of Electronic Supply Chains and Enterprise Resource Planning Systems: The New Business Challenge

Jean C. Essila (2018). *International Journal of Computers in Clinical Practice* (pp. 40-54).

www.irma-international.org/article/the-dynamics-of-electronic-supply-chains-and-enterprise-resource-planning-systems/210559